

DECLARATION DE CONFORMITE DECLARATION OF CONFORMITY

N° A 51 / 2013

APPAREIL(S) : Flush mounting modular boxes
SAMPLE DESCRIPTION :

REFERENCE(S) : 001410-001411-001412-001413-001414-001420-001421-001422-
REFERENCE(S) : 001423-001424-001431-001432-001433-001434-001511-001512-
001513-001514-001521-001522-001523-001524-001531-001532-
001533-001534-602411-602412-602413-602414-602421-602422-
602423-602424-602431-602432-602433-602434-602441-602442-
602443-602444-HL12F-HL24F-HL36F-HL48F

CARACTERISTIQUES : With bent insulating door or metal extra flat door
RATED CHARACTERISTICS :

CET (CES) APPAREIL(S) EST (SONT) CONFORME(S) :
THIS (THESE) DEVICE(S) IS (ARE) IN ACCORDANCE WITH :

the self extinguishing test according to the standard IEC 60695-2-11 (10/2000)

- Flush mounting parts 850°C/30s
- Surface mounting parts 750°C/30s

Cette déclaration comprend : 1 page

This declaration contains : 1 page

Date de délivrance : 18/03/2013
Issue date :

Responsable du Laboratoire Produits Central
Head of test Laboratory
Jean-Marc LIBOUTET



La reproduction de ce document n'est autorisée que sous la forme de fac-similé photographique intégral. Toute reproduction partielle ou toutes insertions de résultats dans un texte d'accompagnement en vue de leur diffusion doit recevoir un accord préalable et formel de LEGRAND. Ce document résulte d'essais effectués sur un échantillon. Il ne préjuge pas de la conformité des produits fabriqués à l'objet essayé.
This document shall not be reproduced, except as a complete photographic facsimile. Any partial reproduction, as well as the insertion of any results into an accompanying text for distribution, requires the prior written approval of LEGRAND.

This document contains results related only to the items tested. It does not imply the conformity of the whole production to the items tested.